



ALMA MATER STUDIORUM
UNIVERSITÀ DI BOLOGNA

ARCHIVIO ISTITUZIONALE DELLA RICERCA

Alma Mater Studiorum Università di Bologna Archivio istituzionale della ricerca

A new climate chamber for air-source and ground-source heat pump testing based on the Hardware-in-the Loop approach: Design and cross validation

This is the final peer-reviewed author's accepted manuscript (postprint) of the following publication:

Published Version:

Dongellini M., Ballerini V., Morini G.L., Naldi C., Pulvirenti B., Rossi di Schio E., et al. (2023). A new climate chamber for air-source and ground-source heat pump testing based on the Hardware-in-the Loop approach: Design and cross validation. JOURNAL OF BUILDING ENGINEERING, 64, 1-17 [10.1016/j.jobe.2022.105661].

Availability:

This version is available at: <https://hdl.handle.net/11585/911641> since: 2023-01-13

Published:

DOI: <http://doi.org/10.1016/j.jobe.2022.105661>

Terms of use:

Some rights reserved. The terms and conditions for the reuse of this version of the manuscript are specified in the publishing policy. For all terms of use and more information see the publisher's website.

This item was downloaded from IRIS Università di Bologna (<https://cris.unibo.it/>).
When citing, please refer to the published version.

(Article begins on next page)

This is the final peer-reviewed accepted manuscript of:

Matteo Dongellini, Vincenzo Ballerini, Gian Luca Morini , Claudia Naldi, Beatrice Pulvirenti, Eugenia Rossi di Schio, Paolo Valdiserri

A new climate chamber for air-source and ground-source heat pump testing based on the Hardware-in-the Loop approach: design and cross validation

In: Journal of Building Engineering, Volume 64, 2023, 105661

The final published version is available online at:

<https://doi.org/10.1016/j.jobe.2022.105661>

© 2023. This manuscript version is made available under the Creative Commons AttributionNonCommercial-NoDerivs (CC BY-NC-ND) 4.0 International License

(<http://creativecommons.org/licenses/by-nc-nd/4.0/>)

This item was downloaded from IRIS Università di Bologna (<https://cris.unibo.it/>)

When citing, please refer to the published version.

1 A new climate chamber for air-source and ground-source heat pump testing
2 based on the Hardware-in-the Loop approach: design and cross validation

3 **M. Dongellini, V. Ballerini, G.L. Morini, C. Naldi, B. Pulvirenti, E. Rossi di Schio*,**
4 **P. Valdiserri**

5
6 Department of Industrial Engineering, Alma Mater Studiorum - University of Bologna,
7 Viale del Risorgimento 2, 40136 Bologna, Italy;

8 matteo.dongellini@unibo.it; vincenzo.ballerini2@unibo.it; claudia.naldi2@unibo.it;
9 beatrice.pulvirenti@unibo.it; gianluca.morini3@unibo.it; eugenia.rossidischio@unibo.it;
10 paolo.valdiserri@unibo.it

11
12 *Correspondence: eugenia.rossidischio@unibo.it; Tel.: +39-051-209-3294

13
14 **Abstract:** The present paper describes a new test bench, designed for experimental tests
15 on small- and medium-sized air-source and ground-source heat pumps, built at the
16 University of Bologna (Italy). The test rig is based on the “Hardware-in-the-Loop” approach
17 and is mainly composed of a test room (i.e. the climate chamber), in which the tested heat
18 pump is placed, a borehole heat exchanger field for tests on ground-source units, the
19 hydraulic loop and the building emulator. The test rig allows to test commercial and
20 prototypal heat pumps under dynamic operating conditions, in order to reproduce the real
21 behavior of a heat-pump based heating system and assess the heat pump effective
22 energy performance. According to the Hardware-in-the-Loop approach, the hydraulic
23 circuit of the facility is designed to reproduce exactly the time-dependent variations of the
24 weather data during a series of representative days in a chosen site and the building
25 thermal load given to the heat pump, calculated by a dynamic simulation software (i.e., the
26 building emulator). In this paper, main components of the experimental facility are
27 presented and the outcomes of a series of numerical simulations carried out with different
28 software, such as Trnsys, Matlab-Simulink and STAR-CCM+, to define the system
29 operative range and the effective behavior of the test bench under dynamic conditions are
30 reported. Numerical models have been validated with experimental data, obtained from a
31 trial test carried out on an air-source heat pump according to current technical standards.
32 Comparison between numerical data and experimental results point out an excellent
33 agreement and, for this reason, numerical models can be used to assess the optimal
34 position of the tested heat pump within the chamber or to define the test bench operating

35 conditions. The cross-validation methodology between experimental data and numerical
36 results from different software, applied in this paper to a test bench for heat pumps, can be
37 employed for the sizing of other test facilities.

38

39 **Keywords:** Climate chamber; Hardware-in-the-Loop, heat pumps, dynamic tests, control
40 strategy, CFD

41

42

43 **1. Introduction**

44 In Europe, the recent REPowerEU Plan [1] aims to fast forward the green transition, by
45 increasing, among the others, from 40% to 45% the headline 2030 target for renewables,
46 fixed by the European Directive 2018/2021 at 32% [2].

47 In this frame, heat pumps can meet the energy demand of buildings, by maximizing the
48 exploitation of renewable energy linked to air, ground or water [3, 4]. In Europe, the most
49 widespread typology is represented by air-source heat pumps (ASHPs), as revealed by
50 recent market data [5]. ASHPs, compared to ground-coupled heat pumps (GCHPs), are
51 cheaper and easier to install, although they have some disadvantages. First of all, the
52 performance of an ASHP is lower when the outside temperature decreases, while the
53 energy demand of the building increases. For this reason, an alternative strategy to design
54 a heating system based on an ASHP could be coupling the heat pump with a back-up
55 system. Dongellini et al. [6] focused on the importance of the correct sizing of the heat
56 pump in presence of both electrical and fossil fuel-based back-up systems to obtain the
57 best seasonal efficiency. Bagarella et al. [7] demonstrated how the heat pump sizing
58 influences the annual performance of hybrid heating systems, in which a gas boiler is used
59 as back-up heater. In addition, they showed that the thermal storage sizing and the
60 transient phenomena linked to the heat pump start-up can influence the annual
61 performance of the system.

62 The frosting phenomenon, particularly in cold and damp climates, is an additional problem
63 of ASHPs [8-10]. Defrosting cycles are usually activated during the winter when the
64 outdoor temperature drops below 6°C and the air relative humidity is higher than 50%. It is
65 well established how defrosting techniques reduce the energy performance of the heating
66 system, as described by Rossi di Schio et al. [9], as well as the thermal comfort in heated
67 environments, as underlined by Vocale et al. [11].

68 Conversely, GCHPs are more efficient than ASHPs, because they are able to use an
69 external thermal source as the ground thermally more stable than air along the year [12].
70 Nevertheless, GCHPs are more expensive than ASHPs, since they need to couple the
71 heat pump with a dedicated borehole heat exchanger (BHE) field. Moreover, the drift of
72 soil temperature can significantly reduce the performance of GCHP systems. As
73 underlined by You et al. [13], in fact, the GCHP energy performance significantly
74 decreases in presence of buildings with unbalanced thermal loads between winter and
75 summer. In case of a predominance of the building heating loads with respect to cooling
76 loads and with a non-optimal sizing of the BHE field, the ground temperature can decrease
77 year by year. This fact introduces a penalization on the energy performance of the GCHP
78 and, in some cases, even to a system failure [13]. Moreover, in a BHE field a crucial role is
79 played by the circuit arrangement [14]. Performance differences between ASHPs and
80 GCHPs have been recently shown by Safa et al. [15] in a comprehensive study,
81 comparing experimental and numerical results, and by Self et al. [16]. In addition, during
82 last years, alternative heat pump solutions have been developed and several works can be
83 found in the open literature. Urban sewage source heat pumps (USSHPs), investigated by
84 Zhao et al [17], solar-assisted heat pumps and trans-critical CO₂ heat pumps, studied by
85 Ran et al. [18] and Quirosa et al. [19], respectively, have been introduced to increase the
86 exploitation of renewable energy sources and reduce carbon emissions in the building
87 sector.

88 A possible solution to the drawbacks of both ASHPs and GCHPs are hybrid systems.
89 These systems can be divided into two categories: (i) hybrid systems composed by
90 multiple generators or (ii) hybrid systems based on a single generator that can exploit
91 different thermal sources (e.g. air and ground with the same device). The latter case can
92 be obtained adopting a dual-source heat pump (DSHP) able to exchange heat with two
93 different external thermal reservoirs. The definition of “dual-source heat pump” has been
94 also used to indicate hybrid systems based on multiple generators, as described by
95 Lazzarin [20]. The author investigated on the energy performance of heating systems
96 based on two heat generators: an ASHP coupled to solar thermal collectors and a GCHP
97 coupled to the same solar collectors field. On the contrary, data about the performance of
98 a DSHP able to exploit energy from different external heat sources are still limited in the
99 literature. Grossi et al. [21] analyzed the seasonal and yearly energy performance of a
100 DSHP able to exploit thermal energy from both the ambient air and the ground, coupled to
101 a one-storey single-family house located in the North of Italy. The authors conducted a

102 series of experimental tests to obtain the characteristic curves of an innovative prototype
103 of DSHP and, according to the experimental results, they designed a Trnsys [22] model for
104 the evaluation of the DSHP energy performance by varying the size of the borehole field
105 and the heat pump control strategy. The performance indicators are compared with those
106 obtained using the DSHP as a full air-source heat pump (air-source mode) or as a full
107 ground-coupled heat pump (ground-source mode) with the aim to explore in which
108 operative conditions a DSHP can be competitive with the conventional monovalent
109 systems based on heat pumps.

110 In the present study, a new test facility has been designed and constructed to evaluate
111 experimentally the energy performance of different typologies of heat pump under dynamic
112 operating conditions. Since in-situ monitoring of heat pump-based systems in occupied
113 residential and commercial buildings is expensive and authorizations from the occupants
114 are strictly needed, the test bench described in this paper is a convenient facility to test the
115 effective behavior of this kind of systems. In fact, as recently underlined by Valdiserri et al.
116 [23], who designed a climate chamber for tests on tracked and wheeled tractors, the
117 development of laboratory facilities for experimental tests is fundamental for both industrial
118 and academic bodies to obtain reliable data.

119 The test rig has been conceived to control the tested heat pump employing a “Hardware-
120 in-the-loop” (HiL) approach. The HiL methodology is a sophisticated and accurate
121 procedure to study the performance of heat pumps coupled to buildings. Haves et al. [24],
122 Lahrech et al. [25] and Anderson et al. [26] have shown that experimental tests on
123 complex heating systems are possible through the use of climate rooms which reproduce
124 on-time the external conditions that the systems would face in the real case. De La Cruz et
125 al. [27] published the implementation of a HiL real-time simulation test bench for heat
126 pumps, demonstrating that this approach is suitable to test innovative control logics for
127 heat pumps and reduce cost and time required for the heat pump development-to-market
128 process. Conti et al. [28] demonstrated the relevance of a dynamic analysis of the building-
129 HVAC system and the potential of the HiL approach in assessing heat pump performance
130 at partial load. Frison et al. [29] tested a model-predictive control algorithm in a HiL
131 environment. Following the approach of the Hardware-in-the-Loop concept, Mehrfeld et al.
132 [30] performed a round-robin test to verify the experimental process and its results for
133 three energy conversion systems: an ASHP, a GCHP and a micro combined heat and
134 power system.

135 . .

136 In the present paper, the layout of a new test bench, based on the HiL approach, and the
137 main features of its components are described. The test rig is suitable to test small- and
138 medium-sized air-source and ground-source heat pumps, as well as dual-source units, by
139 assessing their performance experimentally or by developing innovative control logics. The
140 heat pump under test is placed within a climate chamber (CC), coupled to the hydronic
141 circuit of the test rig. A field made of four vertical borehole heat exchangers (BHEs) is
142 connected to the circuit to test GCHPs in real operating conditions. Finally, a dynamic
143 simulation software, namely the building emulator (BE), is used to calculate the building
144 thermal load and set both the values of air temperature and relative humidity that have to
145 be reproduced in the CC, according to climatic data given by the BE. The role of numerical
146 simulations for the design of the experimental test rig has been crucial. In fact, the
147 behavior of both the climate chamber and the hydronic loop under transient conditions has
148 been evaluated numerically during the design phase by means of two dynamic simulation
149 software. More in detail, Trnsys [22] and Matlab-Simulink [31] have been selected as
150 simulation tools. Each component of the test rig has been modelled with both software,
151 allowing a more precise prediction of the system behavior for design and off-design
152 conditions and a cross-comparison of numerical results. The open-source Simulink
153 toolboxes Carnot [32] ALMABuild [33] have been used to model the whole test bench.
154 Furthermore, in this paper results from an experimental test carried out to determine the
155 performance of a commercial ASHP according to current technical standards are reported
156 as reference. Experimental data have been used to validate a CFD numerical model of the
157 climate chamber, developed with STAR-CCM+. The optimal position of the tested heat
158 pump and the chamber operating conditions have been defined according to numerical
159 outcomes from the model. The cross-validation methodology described in this paper,
160 based on the use of different software, can be employed during the design phase of other
161 test facilities dedicated to heat pump testing.

162

163

164 **2. Experimental test rig**

165 As mentioned in the previous Section, the experimental test rig is composed of a climate
166 chamber, a building emulator and a hydronic loop (HL), coupled to a borehole heat
167 exchanger field.


168

169 *2.1 Climate chamber*

170 The climate chamber is a room having an internal net volume of 78 m^3 , dimensions 6.40 m
171 (length) \times 4.35 m (width) \times 2.80 m (height), for a net floor area of 27.8 m^2 . A simplified
172 layout of the CC is represented in Figure 1. The lateral walls and the ceiling are very well
173 insulated, with a polystyrene layer of 30 cm , in order to reduce the heat transfer between
174 the room and adjacent zones. In Table 1, thermo-physical properties of the climate
175 chamber envelope components are reported. Each wall is identified with an acronym, as
176 shown in Figure 1, from A to D. Only wall D is exposed to external air; other three vertical
177 walls and the ceiling are adjacent to other internal zones of the laboratory, while the floor
178 lies on the ground. Data reported in Table 1 highlight how the U-value of external walls
179 and ceiling is about $0.1 \text{ W/m}^2\text{K}$, while the floor has a transmittance of about $2.31 \text{ W/m}^2\text{K}$.
180 Wall A also presents a door of 2.58 m^2 , thickness equal to 0.07 m and U-value of 0.565
181 $\text{W/m}^2\text{K}$.

182 The hydraulic scheme of the test bench is shown in Figure 2. Inside the CC, three air-
183 heaters (Figure 3a), whose technical specifications are reported in Table 2, are installed
184 (components 1, 2, 3 in Figure 2). Air-heaters have different nominal heating capacity and
185 each of them is equipped with an inverter-driven fan. The air flow rate managed by air
186 heaters ranges between 150 and $12100 \text{ m}^3/\text{h}$. A series of immersed electrode humidifiers
187 are also planned to be installed to maintain the indoor relative humidity at the desired set-
188 point value.

189



190

191 Figure 1. Simplified layout of the climate chamber, with dimensions, wall positions and
192 displacement of devices.

193

194 Table 1. Thickness and thermo-physical properties of the climate chamber envelope
 195 components (layer structure from inside to outside).

Wall/Surface	Envelope Component	Thickness (m)	U- value (W/m ² K)	Thermal conductivity (W/mK)	Density (kg/m ³)	Thermal capacity (J/kgK)
Wall A		0.326	0.104			
	Plasterboard 1	0.013		0.35	1150	1000
	Plasterboard 2	0.013		0.25	740	840
	Insulant	0.300		0.032	32	1700
Wall B		0.546	0.095			
	Plasterboard 1	0.013		0.35	1150	1000
	Plasterboard 2	0.013		0.25	740	840
	Insulant	0.300		0.032	32	1700
	Plaster	0.020		0.9	1800	910
	Thermal blocks	0.200		0.24	780	840
Wall C		0.596	0.092			
	Plasterboard 1	0.013		0.35	1150	1000
	Plasterboard 2	0.013		0.25	740	840
	Insulant	0.300		0.032	32	1700
	Plaster	0.020		0.9	1800	910
	Thermal blocks	0.250		0.21	600	1000
Wall D		0.476	0.100			
	Plasterboard 1	0.013		0.35	1150	1000
	Plasterboard 2	0.013		0.25	740	840
	Insulant	0.300		0.032	32	1700
	Hollow bricks	0.120		0.35	800	1000
	Plaster	0.030		0.9	1800	910
Ceiling		0.526	0.100			
	Plasterboard 1	0.013		0.35	1150	1000
	Plasterboard 2	0.013		0.25	740	840
	Insulant	0.300		0.032	32	1700
	Concrete	0.180		0.59	1600	1000
	Mortar	0.020		0.73	1850	1000
Floor		0.123	2.306			
	Mat	0.005		0.17	1200	1400
	Insulant	0.018		0.38	1200	840
	Dry screed	0.020		0.39	1850	1000
	Concrete	0.080		0.59	1600	1000


196

197

198 2.2 Hydraulic scheme of the test rig

199 Since the main application of the climate chamber is to study the behavior of heat pumps
 200 under dynamic operating conditions, it is mandatory to control the ambient conditions
 201 within the CC when an ASHP is tested, using both air heaters and humidifiers. In fact,
 202 when an ASHP is operated in heating mode, the CC air temperature is reduced by the
 203 evaporation of the refrigerant fluid. To maintain the CC temperature at the desired value,
 204 the heat supplied by the heat pump condenser can be used. The hot water produced by
 205 the heat pump is used to feed the air heaters placed in the chamber through the hydronic
 206 loop shown in Figure 2. In this way, the CC air temperature can be controlled balancing
 207 the heat absorbed by the heat pump with that introduced in the chamber by internal air
 208 heaters. Internal air temperature can be modified by varying the air heaters fan speed,
 209 increasing or decreasing the heat supplied.

210



211

212 Figure 2. Hydraulic scheme of the experimental test rig (climate chamber within the red
 213 line).

214

215 In order to stabilize the system operation, a water thermal energy storage (TES) tank (hot
 216 water TES in Figure 2) is introduced in the hydronic loop. The tank has a volume of 0.5 m³
 217 (Figure 3b) and the hot water produced by the heat pump flows in a coiled heat exchanger,
 218 immersed within the tank, having a total external surface equal to 6 m² and a length of 60
 219 m. The hot water TES is equipped with an electric resistance, having a heating capacity of
 220 6 kW, used to provide additional energy when the heat delivered by the heat pump is not
 221 sufficient to maintain the CC temperature at the required value. The resistance also
 222 support the system during warm-ups and in particular operating conditions.

223 When CC air temperature has to be reduced, internal air-heaters fan speed decreases
 224 and, for this reason, the heat produced by the tested heat pump is discharged to the
 225 environment by means of three external air-heaters (components 4, 5 and 6 in Figure 2).
 226 Technical data of the six air-heaters installed in the test rig are reported in Table 2.

227

228

229

(a)



(b)



230 Figure 3. Air-heaters inside the climatic chamber (a) and the hydronic loop of the test rig
231 (b).

232

233 When ambient air conditions do not guarantee the required heat transfer rate, an air-to-
234 water inverter-driven chiller is operated. The conditioning unit is connected to a second
235 thermal energy storage tank, having a volume of 0.5 m^3 (cold water TES in Figure 2). The
236 cold water TES guarantees the stable operation of the system also when the chiller
237 performs on-off cycles (i.e. when a low cooling power is needed). Table 3 reports the rated
238 performance data of the chiller.

239 Temperature sensors and electromagnetic flow meters (Siemens, SITRANS F M MAG
240 1100, range 0-10 m/s, accuracy $0.2\% \pm 1 \text{ mm/s}$) are installed in the hydronic loop to
241 check the operation of the whole system during experimental tests and to measure the

242 energy performance of the tested heat pump. A power meter has been also installed in the
 243 laboratory (Fluke 1735 three-phase power quality logger, accuracy $\pm 1\%$) to analyze the
 244 electric power input of the heat pump under test.

245 T-type thermocouples and RTD Pt100 (accuracy class 1/10 DIN) calibrated in the range
 246 from -5°C to 50°C with an uncertainty of $\pm 0.15\text{ K}$ [34], are installed in the test bench.

247 When a GCHP or a DSHP (operating in ground mode) is tested, the heat pump heating
 248 capacity is dissipated thanks to the chiller or the external air-heaters. In this operation
 249 mode it is not necessary to control the CC conditions. In fact, when the heat pump
 250 operates in ground mode, the external heat source is the soil and heat is extracted through
 251 four vertical borehole heat exchangers (BHEs, see Figure 4). Different lengths of the
 252 vertical borefield can be considered: it is possible to combine, in different ways, two 100 m
 253 long and two 60 m long boreholes, obtaining undersized as well as oversized fields, to
 254 check the influence of BHE size on the heat pump performance.

255 Table 4 reports the technical data of the utilized measuring instruments: manufacturer,
 256 model, measuring range and uncertainty.

257

258 Table 2. Technical datasheet of internal and external air-heaters (Rated conditions: inlet
 259 air temperature = 15°C and inlet/outlet water temperature = $85\text{-}75^{\circ}\text{C}$).

Component	Modulation capability [%]	Rated heating capacity [W]	Maximum power absorbed [W]	Model	Location
Air-heater 1	20-100	11200	80	Galletti AREO12M0ECC0	Climate chamber
Air-heater 2	20-100	18700	139	Galletti AREO22M0ECC0	Climate chamber
Air-heater 3	20-100	67000	840	Galletti AREO43T0ECC0	Climate chamber
Air-heater 4	20-100	11200	80	Galletti AREO12M0ECC0	Outside the laboratory
Air-heater 5	20-100	18700	139	Galletti AREO22M0ECC0	Outside the laboratory
Air-heater 6	20-100	67000	840	Galletti AREO43T0ECC0	Outside the laboratory

260

261 Table 3. Technical data of the chiller (rated conditions: ambient air temperature = 35°C ,
 262 inlet/outlet water temperature = $12/7^{\circ}\text{C}$).

Component	Frequency range [Hz]	Rated EER	Rated cooling capacity [W]	Maximum power [W]	Model	Location
Chiller	20-120	2.38	18200	22000	Galletti MPIDC018C0A	Outside the laboratory

263

264 Table 4. Technical data of the measuring instruments, including measuring range and
 265 uncertainty.

Model/sensor	Type	Range	Accuracy
Siemens SITRANS F M MAG 1100	Electromagnetic flow meter	0 – 10 m/s	0.2% ± 1 mm/s
Fluke 1735 three-phase power quality logger	Power meter	0 – 34.5 kW	± 1 %
RTD	Pt100 1/10 DIN	0 – 90 °C	± 0.03 K (at 0°C)
Thermocouples	T-type	0 – 90 °C	± 0.15 K



(a)



(b)

268 Figure 4. Vertical borehole heat exchangers (a) and supply and return manifolds coupled
 269 to the boreholes field (b).

270

271 It is worth to mention that a Distributed Temperature Sensing (DTS) system is installed in
 272 the BHE field to measure the fluid thermal progression along different boreholes. More in
 273 detail, fiber optical cables are inserted inside two BHEs of different length (one 100 m and
 274 one 60 m long), Fiber optics are placed along the entire U-tube of the boreholes,
 275 measuring the fluid temperature distribution as a function of time when a heat pump is
 276 tested in ground-source mode and allowing to evaluate the depth-specific BHE thermal
 277 conductivity and thermal resistance [35].

278 The installed DTS system (SMARTEC, DiTemp Light Reading Unit) has a minimum spatial
279 resolution of 2 m and a measurement time higher than 10 s. Temperature measurement
280 accuracy depends on the calibration procedure, made with the same RTD Pt100 used for
281 thermocouples calibration. DTS technology is based on Raman scattering, which occurs
282 when the optical pulse energy is modified by changes in vibrational transition energy,
283 caused by temperature variations. The ratio between stokes and anti-stokes Raman
284 scattering is used to calculate the temperature, in conjunction with the time taken by the
285 optical pulse to travel back to the DTS control unit.


286

287 **3. Tests on ASHPs in steady-state conditions**

288 In this Section, results of experimental tests carried out on an ASHP to determine its
289 energy performance in steady-state condition, according to European standard UNI EN
290 14511-3 [36], are shown as a demonstrator of the potentiality of the test bench described
291 in this work.


292 Several T-type thermocouples have been placed in the climate chamber to obtain accurate
293 data on air temperature distribution. In Figures 5 and 6, the position of thermocouples is
294 shown. The only readings used for the test evaluation according to standard [36] are
295 sampled from thermocouples 1, 2, 4, 5, 8, 9 shown in Figures 5-6; those temperature
296 sensors are placed in proximity of the evaporator of the heat pump under test. Data taken
297 from the other thermocouples have no impact on the test outcomes but are useful to
298 determine the temperature distribution in the chamber, as explained in the following
299 sections.

300



301
 302 Figure 5. Position of the thermocouples (red dots) in the CC.

303



304
 305 Figure 6. Position of the thermocouples (red dots) in proximity of the HP evaporator.

306



307

308 Figure 7. Heat pump inside the climate chamber (prototype based on mod. HWMC 010
309 HM).


310


311 The tested heat pump (Figure 7) is an air-source heat pump prototype, equipped with an
312 inverter-driven compressor, and uses R-410A as refrigerant. The nominal thermal power is
313 11.4 kW, evaluated in the following conditions: air dry bulb and wet bulb temperature equal
314 to 7°C and 6°C, respectively, water inlet and outlet temperature equal to 40°C and 45°C,
315 respectively. In Figure 8, values of thermal power and COP given by the manufacturer are
316 reported as functions of the external air temperature, for different inverter frequencies.

317

318

(a)





319 Figure 8. COP and thermal power output for the tested ASHP, referring to (a) inlet and
 320 outlet water temperature of 30 and 35°C, (b) inlet and outlet water temperature of 40 and
 321 45°C.


322
 323 Tests on the ASHP are carried out according to standard UNI EN 14511-3 procedure. The
 324 standard abovementioned prescribes to determine the heating capacity (P_{th}) of the air-to-
 325 water heat pump at the water side, measuring the water temperature difference (ΔT) and
 326 the water mass flow rate (\dot{m}) at the condenser of the heat pump under test, as follows:

$$P_{th} = \dot{m}c_p\Delta T \quad (1)$$

327 In Eq. (1), c_p is the specific heat capacity at constant pressure of the water flowing in the
 328 condenser, assumed constant during tests (4186 J/(kgK)).


329 Following the procedure reported in Eurovent technical standards for heat pump testing
 330 [37], sleeves for water temperature and pressure measurements at the heat pump inlet
 331 and outlet have been manufactured.

332



333

(a)



(b)

334

335 Figure 9. Sleeves for water temperature and pressure measurements at heat pump outlet
 336 (a) and inlet (b)

337

338 A scheme of the sleeves is reported in Figure 9. More in detail, each sleeve is composed
 339 by a plug for pressure measurements, located close to the heat pump, a diaphragm and a
 340 tube for the positioning of RTD temperature sensors. As pointed out by the figure,
 341 pressure plugs are installed close to the heat pump outlet/inlet ports in order to measure
 342 water pressure drops on the unit under test side. Furthermore, a diaphragm is inserted
 343 before each temperature sensor to introduce turbulence and, consequently to achieve
 344 uniform temperature measurements. According to the methodology reported by standard
 345 [37], temperature sensors are installed within an elbow, in a counterflow arrangement, and
 346 have a length of 100 mm. The distance between each diaphragm and the corresponding
 347 tube for temperature sensor housing is higher than 8 diameters. The standard also
 348 prescribes the test procedure, the specifications of the climate room and the admitted
 349 tolerances of the measuring equipment. An important aspect related to the climate
 350 chamber refers to the internal air flow distribution. The heat pump must be located away
 351 from the walls, with a minimum distance of 1 m, the air speed must be lower than 1.5 m/s
 352 and the air-heaters must not be placed close to the temperature sensors. The allowed
 353 measure uncertainties are specified in Table 5. At least 4 measuring points of the air
 354 temperature are necessary and sensors must be placed close to the evaporator of the
 355 heat pump under test (within 25 cm), evenly spaced.

356

357 Table 5. Maximum admitted uncertainty of measurement, prescribed by standard UNI EN
 358 14511-3 [36].

Measured quantity	Maximum admitted uncertainty	Unit
Air dry bulb temperature	±0.2	K

Liquid inlet/outlet temperature	±0.15	K
Liquid temperature difference	±0.15	K
Liquid volume flow	±1%	
Electric power	±1%	

359

360 Tests in steady-state condition have been carried out for 70 minutes, collecting
 361 measurements every 30 s. In order to guarantee stationary conditions, test procedure
 362 reported by the standard [36] prescribes maximum fluctuations of temperature readings
 363 along the test. Table 6 shows the amplitude of allowed fluctuations. More in detail, two
 364 limits are reported by the standard: each single measurement should be included within a
 365 punctual range, while the average fluctuation along the test should be lower than the mean
 366 limit reported in Table 6.

367

368 Table 6. Maximum admitted measurement fluctuations during tests.

	Punctual	Mean
Inlet water temperature	±0.5 K	±0.2 K
Outlet water temperature	± 0.3 K	± 0.6 K
Air dry-bulb temperature	±1 K	±0.3 K

369

370 In addition, the standard prescribes to determine for every 5 minutes of the test the
 371 temperature difference between the water outlet and inlet of the heat pump. The mean
 372 temperature differences, measured every 5 minutes, are employed to determine the
 373 percentage temperature difference with respect to the mean temperature difference of the
 374 first 5 minutes of the test, using Eq.(2), where ΔT_0 refers to the mean value of the first five
 375 minutes and $\Delta T_i(\tau)$ refers to the mean temperature difference of the following 5 minutes
 376 intervals of the entire test,

$$\Delta T_{i,\%} = 100 \frac{\Delta T_0 - \Delta T_i(\tau)}{\Delta T_0} \quad (2)$$

377 Standard EN 14511-3 prescribes that all the percentage temperature differences $\Delta T_{i,\%}$
 378 must be less than 2.5%.

379

380 Table 7. Test conditions of the ASHP.

	Test 1	Test 2
Inlet water temperature	30 °C	40 °C
Outlet water temperature	35 °C	45 °C
Air dry-bulb temperature	7 °C	12 °C

381

382 Two tests have been carried out on the ASHP, to determine heat pump performance (i.e.,
 383 heating capacity and *COP*) at full load. Operating conditions of both tests are reported in
 384 Table 7. In Table 8 minimum, maximum and mean temperature values of both air and
 385 water side during performed tests are reported.

386

387 Table 8. Mimimum, maximum and mean temperature values during tests.

Thermocouple	Test 1			Test 2		
	Min (°C)	Max (°C)	Mean (°C)	Min (°C)	Max (°C)	Mean (°C)
TC 1 (air - evaporator)	5.9	7.0	6.4	10.9	12.0	11.3
TC 2 (air - evaporator)	5.9	7.3	6.6	10.8	12.5	11.5
TC 4 (air - evaporator)	6.5	7.6	7.0	11.3	12.7	11.9
TC 5 (air - evaporator)	6.1	7.0	6.4	11.2	12.7	11.8
TC 8 (air - evaporator)	6.3	7.8	7.0	11.5	12.4	12.0
TC 9 (air - evaporator)	6.2	7.6	6.9	11.5	12.6	12.0
RTD 6 (HP water inlet)	29.9	30.2	30.0	40.0	40.2	40.1
RTD 7 (HP water outlet)	34.7	35.1	34.9	44.9	45.2	45.1

388

389 Results reported in Table 8 point out that for Test 1, TC 1 and TC 2 do not respect the
390 prescribed tolerances, both for a single measure during the test and for the mean value.
391 Moreover, also the average temperature value given by TC 5 does not respect the
392 tolerance prescribed. On the contrary, if results of Test 2 are considered, punctual and
393 mean limits are not satisfied by measures of TC 1 and TC 2. This aspect can be attributed
394 to the non-uniform distribution of air temperature in the climate chamber and will be better
395 investigated in the next section by means of CFD simulations.

396 In Table 9, values of absolute and relative water temperature difference between outlet
397 and inlet of the heat pump are reported. Results show that the relative temperature
398 difference was always less than 2.5% for the two tests carried out, as prescribed by the
399 standard.

400 Finally, the energy performance of the tested ASHP are reported in Table 9, by
401 considering the uncertainty propagation theory. In this table, the values of heating capacity
402 and *COP* given by the heat pump manufacturer are reported as well.

403

404

405 Table 9. Water temperature difference between the ASHP inlet and outlet during tests.

Time (min)	Test 1		Test 2	
	ΔT_i (K)	$\Delta T_{i,\%}$ (%)	ΔT_i (K)	$\Delta T_{i,\%}$ (%)
5	4.90	-	4.99	-
10	4.88	0.47	5.00	-0.13
15	4.88	0.48	5.00	-0.12
20	4.86	0.74	5.00	-0.31
25	4.87	0.66	5.00	-0.22
30	4.89	0.18	4.99	0.05
35	4.88	0.46	4.99	0.03
40	4.89	0.16	4.99	-0.11
45	4.89	0.22	4.98	0.16
50	4.89	0.28	4.99	0.03
55	4.89	0.22	5.01	-0.35
60	4.89	0.24	5.00	-0.15
65	4.90	-0.06	4.98	0.12
70	4.89	0.12	5.00	-0.29

406

407

408 Table 10. Results from Test 1 and Test 2 compared to manufacturer data.

	Test 1 (experimental data)	Test 2 (experimental data)	Test 1 (declared by manufacturer)	Test 2 (declared by manufacturer)
Heating capacity (W)	10750±1370	11655±1450	11300	12300
COP (-)	3.48±0.52	3.16±0.46	3.98	3.55

409


410 Data in Table 10 show that the heat pump energy performance calculated experimentally
 411 is lower than that declared by the manufacturer. Nevertheless, these values are in the
 412 range of the test results, if typical uncertainties values are considered. However we should
 413 note that, usually, manufacturers avoid to provide the accuracy range of the main nominal
 414 parameters indicated in their datasheet.

415


416 **4. CFD analysis of air velocity and temperature field in the climate chamber**

417 In this section, the results of CFD simulations, carried out by means of the software STAR-
 418 CCM+, are presented to study the air flow dynamics and the temperature distribution in the
 419 climate chamber during the test described before. The computational domain is shown in
 420 Figure 10, where the climate chamber is shown from two opposite views. The right hand
 421 side of the figure shows the ground, two vertical walls and the devices used for the air
 422 conditioning, i.e. the heat pump on the right and three air-heaters on the left. The left hand
 423 side of the figure shows the opposite view of the same room. The boundary conditions are
 424 the followings: a volume flow inlet from the air-heater equal to 1626 m³/h (shown in red in
 425 the figure) and a volume flow rate from the heat pump equal to 7104 m³/h (shown in blue).
 426 Moreover, outlet boundary conditions at the blue section in the air-heater and at the yellow
 427 section in the heat pump. The thermal power given to the inlet flow at the air-heater is 6.9
 428 kW while the thermal power absorbed by the evaporator from the CC air is 8.35 kW. The
 429 transmittance of the walls has been set to 0.1 W/m² K, with an external temperature set to
 430 30 °C.

431



432



433

434

435 Figure 10. Two opposite views of the computational domain (top) and the mesh (bottom).

436 Mesh of the elements and on the walls (bottom left) and on a horizontal section at 1 m


437 (bottom right) .

438

439 Climate chamber envelope components are treated as walls with U-values obtained
440 combining data shown in Table 1: the transmittance of floor and vertical walls is defined
441 equal to $2 \text{ W/m}^2\text{K}$ and $0.1 \text{ W/m}^2\text{K}$, respectively. The numerical simulations refer to the CC
442 in a steady-state condition with a set-point temperature of 12°C . An unstructured mesh
443 with polyedral elements has been built, as shown in Fig. 10.

444 The figure shows that three refinement zones have been considered, starting from the heat
445 pump. A similar refinement zone have been built around the air-heater. A mesh
446 convergency analysis has been made, starting from a mesh with 5 millions of elements up
447 to a mesh with 25 millions of elements. The converged computational mesh has 20 million
448 of elements. The Reynolds stress model has been used for modelling the turbulence, as it
449 represents the most complete classical turbulence model. By this model, the eddy
450 viscosity approach is avoided and the individual components of the Reynolds stress tensor
451 are directly computed, to account for complex interactions in turbulent flow fields, such as
452 the directional effects of the Reynolds stresses.

453




454 Figure 11. Streamlines obtained at the heat pump outlet (top, left), at the air-heater inlet
 455 (top, right), at the air-heater outlet (bottom, left) and at the heat pump inlet (bottom, right).
 456 The streamlines are coloured with the air temperature in Celsius degrees.


457
 458 The streamlines coloured by the temperature obtained at the heat pump outlet are shown
 459 in Figure 11 top, left. The figure shows that the inlet cold air stream coming from the heat
 460 pump flows towards the wall, then, it is divided in two parts. The mainstream flows along
 461 the wall opposite to the side where the heaters are placed. The secondary stream flows
 462 along the opposite flow and is collected by the air-heater, as shown in Figure 11, top, right.
 463 Part of this stream is mixed with the flow coming from the air-heater in a vortex near the
 464 heat pump, as shown in Figure 11, bottom, left. The mainstream is then collected almost
 465 entirely by the heat pump, as shown by Figure 11, bottom, right. Figure 12 shows the
 466 velocity magnitude distribution and the vectors obtained on a horizontal plane at $z=1$ m.
 467 The velocity is less than 1.5 m/s, as requested by the standard UNI EN 14511-3. This
 468 plane is important because it is at a height where the devices which are tested within the
 469 climatic chamber are placed.

470 Figure 13 shows the air temperature distribution within the CC, obtained on horizontal
 471 planes at heights $z=1$ m and $z=1.5$ m. The temperature distribution obtained in the region
 472 between the heat pump and the wall where the heaters are placed is uniform with a value
 473 of 12 °C.


474



475




476



477
478
479
480
481

Figure 12. Velocity magnitude obtained on a horizontal plane at $z=1.5$ m (top), vectors on the same plane (middle) and static pressure distribution (bottom).



482
483
484
485
486
487
488
489
490
491

Figure 13. Temperature obtained on horizontal planes at $z=1$ m (left) and $z=1.5$ m (right).

Figures 11 and 12 show that there is a portion of the chamber near the heat pump where a strong peak of the velocity field is found. On the other side, the velocity and temperature fields are uniform. The vector map shown in Fig. 12 shows a zone with uniform velocity between two vortices. Near the wall this uniform velocity field shows velocities smaller than 0.5 m/s, with a uniform temperature distribution, as shown by fig. 13. In this region, also the static pressure is uniform, and this confirms the fact that the indicated area can be used for positioning the equipment to be tested in the climatic chamber. According to this outcome, it can be concluded that the optimal position of the heat pump under test has


492 been identified. This methodology can be helpful to assess the optimal installation of other
493 heat pumps tested in the facility and, moreover, can predict whether the heat pump
494 performs better in different positions with respect to that used in the tests described in this
495 work. Furthermore, simulations show that the configuration implemented within the climate
496 chamber (i.e., internal air-heaters placed on a side wall and tested heat pump on the
497 opposite side of the chamber) can guarantee a controlled air temperature distribution
498 within a zone in the room between the heater and the heat pump. Three positions have
499 been chosen as representative of the average temperature of the chamber. These
500 positions are shown in Figure 14 and the correspondent temperatures and velocities are
501 shown in Table 11. These values have been compared with the measurements in order to
502 validate the CFD simulations.

503

504 *4.1 Comparison between CFD simulation and measured air temperature values in the CC*

505 If we consider an enlarged view of Figure 13, considering the air temperature distribution
506 at $z=1$ m from the floor and in proximity of the evaporator inlet (Figure 14), it can be
507 noticed an uniform temperature of about 12°C , that is approximately the same that was
508 obtained by experimental data acquisition for the three thermocouples located at the heat
509 pump evaporator inlet during the whole test 2 (TC 2, TC 4 and TC 8), as reported in Table
510 10.

511



512

513 Figure 14. Temperature distribution in proximity of the evaporator inlet, at z=1 m from the
514 floor.

515

516 Table 11. Mean air temperature values in proximity of the evaporator (mean value for the
517 whole duration of test 2), temperature and velocity data obtained by CFD simulation.

Thermocouple	Velocity (m/s) CFD simulation	Temperature (°C) CFD simulation	Temperature (°C), test 2
TC 2	0.7	11.95	11.48
TC 4	0.8	12.09	11.88
TC 8	0.5	12.37	11.97


518

519 It can be observed that the measured temperature values are in good agreement with
520 those obtained by CFD simulations. It can be concluded that these thermocouples provide
521 an accurate indication of the average air temperature at the heat pump inlet and, for this
522 reason, hose sensors can be taken as a reference to identify the setpoint temperature for
523 the climatic chamber control. The measurements from the other thermocouples can be
524 integrated to optimize the air flows in the chamber.

525

526 *4.2. Dynamic simulations of the air temperature trend within the climate chamber*

527 In order to investigate the trend of the air temperature in the climate chamber during a test,
528 a numerical model of the climate chamber has been set up with Trnsys. In this model the
529 climate chamber is considered as a single node characterized by a single value of internal
530 air temperature which indicates the mean value of the air temperature in the room. Results
531 given by the model are compared with experimental temperature measurements in the
532 climate chamber with the aim to check if the thermal model of the climatic chamber made
533 in TRNSYS is able to reproduce the observed experimental temperature trend within the
534 chamber. The Trnsys model layout is reported in Figure 15.



535

536 Figure 15. Layout of the Trnsys model for the analysis of climate chamber behavior.


537

538 The climate chamber envelope components are modelled by means of Trnsys Multizone
 539 building (type 56) by using the data reported in Table 1. The air change rate within the
 540 chamber is unknown and one of the indirect goals of this comparison is to use the
 541 experimental data to set the real value of the air change rate.

542 Dynamic simulations and experimental measurements aim to analyze the temperature
 543 variation in the CC when the mean air temperature value in the room (measured by 8
 544 thermocouples, TC 17, TC 18, TC 22, TC 25, TC 27, TC 28, TC 30 and TC 32) reaches a
 545 steady-state value of 4°C and both air heaters and heat pump are switched off with an
 546 ambient temperature of 26.5°C. The time-step between measurements is set to 300 s. The
 547 dynamic simulations have been carried out assuming a time-step of 300 s, for a total of 60
 548 h (the same of the experimental data acquisition). The air temperature inside the CC and
 549 the temperature of the air given by TRNSYS model are reported in Figure 16 as a function
 550 of time. We can observe a good agreement with experimental temperature measurements
 551 and simulated air temperature values if an air change rate of 0.5 h⁻¹ is imposed. The mean
 552 percentage relative difference between experimental and numerical data is about 2%.
 553 After 60 h the mean temperature within the chamber reaches 21°C, 6.6 K less than the
 554 ambient temperature. During the first 13 hours after the switch-off, temperature tends to
 555 increase with an average rate of 1.06 K/h. This value is important for the correct setup of

556 the CC control system. These results confirm the good thermal insulation level of the
557 climate chamber.

558



559

560 Figure 16. Comparison between measured and simulated climate chamber air
561 temperature.

562

563 5. Conclusions

564 In this paper, the layout and the working principle of a new experimental test rig, designed
565 and realized at the University of Bologna, Italy, are described. The main purpose of the set-
566 up is to test air-source and ground-coupled heat pumps, having a rated heating capacity
567 lower than 12 kW, through the Hardware-in-the-Loop approach. Main elements of the test
568 rig are: a highly-insulated climate chamber, in which the tested heat pump is placed; the
569 hydraulic circuit used to manage the system; the building emulator, by means of which the
570 thermal load of a building is calculated through dynamic simulations and given to the loop;
571 a borehole heat exchanger field for tests on ground-source heat pumps.

572 In this paper, the importance of numerical simulation software, such as Trnsys, Matlab-
573 Simulink and STAR-CCM+, in the design of the climate chamber has been also
574 demonstrated. It has been shown that numerical simulations are important during the

575 design phase of this kind of test rigs and, moreover, dynamic simulations are pivotal also
576 for the setup of the Hardware-in-the Loop control system. Then, some experimental
577 measures on a commercial air-source heat pump, carried out according to current
578 standard UNI EN 14511-3, are described as trial test for the facility. Numerical models
579 have been then validated with experimental data. The comparison between experimental
580 results and data reported in the manufacturer datasheet confirms a good agreement,
581 pointing out the reliability of the test rig described in this work. With the help of CFD, air
582 velocity and temperature distribution within the room have been obtained as a function of
583 the position of the heat pump in the chamber and of the activated air-heaters. Outcomes of
584 this work demonstrate how a cross-validation methodology combining numerical and
585 experimental data is crucial during the design phase of test facilities as the one presented
586 in this paper. In fact, according to that methodology, the uniformity of temperature
587 distribution within the chamber and the air velocity field close to the heat pump can be
588 verified in order to assess the optimal position of the heat pump within the room. Finally, it
589 is expected that the HiL system described in this paper will become an important design
590 tool for heat pump manufacturers to evaluate experimentally the effective performance of
591 heat pump-based HVAC systems.

592

593 **Acknowledgements**

594 The research leading to these results has received funding from MUR within the
595 framework of the PRIN2017 project «The energy FLEXibility of enhanced HEAT pumps for
596 the next generation of sustainable buildings (FLEXHEAT)», grant 2017KAAECT.

597

598 **Nomenclature**

599	A, B, C, D	walls of the climate chamber
600	ASHP	air-source heat pump
601	BE	building emulator
602	BHE	borehole heat exchanger
603	CC	climate chamber
604	<i>COP</i>	coefficient of performance of a heat pump
605	c_p	specific heat capacity at constant pressure [J/(kg K)]
606	DSHP	dual source heat pump
607	DTS	Distributed Temperature Sensing system
608	GSHP	ground-source heat pump

609	HiL	hardware-in-the-loop
610	\dot{m}	mass flow rate [kg/s]
611	P_{th}	heating capacity of an air-to-water heat pump [W]
612	Q	thermal power [W]
613	TC	thermocouple
614	Z	vertical coordinate [m]
615	ΔT	water temperature difference [K]
616	ΔT_0	mean water temperature difference of the first five minutes of test
617	$\Delta T_i(\tau)$	mean water temperature difference of the following 5 minutes intervals
618		of the entire test

619
620

621 **References**

- 622 [1] European Parliament and Council. REPowerEU Plan. Communication from the
623 Commission to the European Parliament, the European Council, the European Economic
624 and Social Committee and the Committee of the Regions, [https://eur-lex.europa.eu/legal-](https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=COM%3A2022%3A230%3AFIN&qid=1653033742483)
625 [content/EN/TXT/?uri=COM%3A2022%3A230%3AFIN&qid=1653033742483](https://eur-lex.europa.eu/legal-content/EN/TXT/?uri=COM%3A2022%3A230%3AFIN&qid=1653033742483) (Accessed
626 August 29th 2022)
- 627 [2] European Parliament and Council. 2018. Directive (EU) 2018/2001 of the European
628 Parliament and of the Council of 11 December 2018 on the promotion of the use of energy
629 from renewable sources. Official Journal of the European Union.
- 630 [3] I. Sarbu, C. Sebarchievici, General review of ground-source heat pump systems for
631 heating and cooling of buildings, Energy Build 70 (2014),441–454.
- 632 [4] P. Carroll, M. Chesser, P.Lyons P, Air Source Heat Pumps field studies: A
633 systematic literature review, Renew Sust Energ Rev 134 (2020), 1-12.
- 634 [5] European heat pump association (EHPA). European heat pump market and
635 statistics report, 2021, <https://www.ehpa.org/market-data/market-report-2021/> (Accessed
636 August 29th 2022).
- 637 [6] M. Dongellini, C. Naldi, G.L. Morini, Influence of sizing strategy and control rules on
638 the energy saving potential of heat pump hybrid systems in a residential building, Energy
639 Convers Manag 235 (2021):114022.
- 640 [7] G. Bagarella, R. Lazzarin, M. Noro, Sizing strategy of on-off and modulation heat
641 pump systems based on annual energy analysis, Int J Refrig 65 (2016),183-193.

- 642 [8] Y. Zhang, G., Zhang, A. Zhang, Y. Jin, R. Ru, M. Tian, Frosting phenomenon and
643 frost-free technology of outdoor air heat exchanger for an air-source heat pump system in
644 China: An analysis and review, *Energies* 11 (2018), 1-36.
- 645 [9] E. R. Di Schio, V. Ballerini, M. Dongellini, P. Valdiserri, Defrosting of air-source heat
646 pumps: Effect of real temperature data on seasonal energy performance for different
647 locations in Italy, *Appl Sci* 11 (2021) 8003.
- 648 [10] Z. Xi, R. Yao, J. Li, C. Du, Z. Yu, B. Li, Experimental studies on hot gas bypass
649 defrosting control strategies for air source heat pumps, *J. Build. Eng.* 43 (2021) 103165.
- 650 [11] P. Vocale, G.L. Morini, M. Spiga, Influence of outdoor air conditions on the air
651 source heat pumps performance, *Energy Procedia* 45 (2014), 653-662.
- 652 [12] M. Lucchi, M. Lorenzini, P. Valdiserri, Energy performance of a ventilation system
653 for a block of apartments with a ground source heat pump as generation system, *J Phys*
654 *Conf Ser* 796 (2017), 1-9.
- 655 [13] T. You, W. Wu, W. Shi, W. Baolong, X. Li, An overview of the problems and
656 solutions of soil thermal imbalance of ground coupled heat pumps in cold regions, *Appl*
657 *Energy* 177 (2016) 515-536.
- 658 [14] A. Jahanbin, G. Semprini, A.N. Impiombato, C. Biserni, E.R. Di Schio, Effects of
659 the circuit arrangement on the thermal performance of double U-tube ground heat
660 exchangers, *Energies* 13 (2020) 3275.
- 661 [15] A.A. Safa, A.S. Fung, R. Kumar, Comparative thermal performances of a ground
662 source heat pump and a variable capacity air source heat pump systems for sustainable
663 houses, *Appl Therm Eng* 81 (2015) 279-287.
- 664 [16] S.J. Self, B.V. Reddy, M.A. Rosen, Geothermal heat pump systems: Status review
665 and comparison with other heating options, *Appl Energy* 101 (2013) 341-348.
- 666 [17] X. L., L. Fu, S.G. Zhang, Y. Jiang, Z.L. Lai, Study of the performance of an urban
667 original source heat pump system, *Energy Convers Manag* 4 (2010) 765-770.
- 668 [18] S. Ran, W. Lyu, X. Li, W. Xu, B. Wang, A solar-air source heat pump with
669 thermosiphon to efficiently utilize solar energy, *J. Build. Eng.* 31 (2020), 101330.
- 670 [19] G. Quirosa, M. Torres, V.M. Soltero, R. Chacartegui, Energetic and economic
671 analysis of decoupled strategy for heating and cooling production with CO₂ booster heat
672 pumps for ultra-low temperature district network, *J. Build. Eng.* 45(2022), 103538.
- 673 [20] R.M. Lazzarin, Dual source heat pump systems: Operation and performance.
674 *Energy Build* 52 (2012) 77-85.

- 675 [21] I. Grossi, M. Dongellini, A. Piazzzi, G.L. Morini, Dynamic modelling and energy
676 performance analysis of an innovative dual-source heat pump system, *Appl Therm Eng*
677 142 (2018) 745-759.
- 678 [22] S.A. Klein, W.A. Beckman, J.W. Mitchell, J.A. Duffie, N.A. Duffie, T.L. Freeman,
679 J.C. Mitchell, J.E. Braun, B.L. Evans, J.P. Kummer, et al., TRNSYS Version 18; Solar
680 Energy Laboratory, University of Wisconsin-Madison: Madison, WI, USA (2018).
- 681 [23] P. Valdiserri, E.R. Di Schio, V. Rondelli, E. Capacci, A numerical analysis for the
682 design of a climatic chamber, *AIP Conference Proceedings* 2191 (2019), 020150.
- 683 [24] P. Haves, A. Dexter, D.R. Jorgensen, K.V. Ling, G. Geng, Use of a building
684 emulator to develop techniques for improved commissioning and control of HVAC system,
685 *ASHRAE Transaction* 97 (1991) 684-688.
- 686 [25] R. Lahrech, P. Gruber, P. Riederer, P. Tessier, J.C. Visier, Development of a testing
687 method for control HVAC systems by emulation, *Energy Build* 34 (2002) 909-916.
- 688 [26] M. Anderson, M. Buehner, P. Young, D. Hittle, C. Anderson, J. Tu, D. Hodgson, An
689 experimental system for advanced heating, ventilating and air conditioning (HVAC) control,
690 *Energy Build* 39 (2007) 136-147.
- 691 [27] A.T. De La Cruz, P. Riviere, D. Marchio, O. Cauret, A. Milu, Hardware in the loop
692 test bench using Modelica: A platform to test and improve the control of heating systems,
693 *Appl Energy* 188 (2017) 107-120.
- 694 [28] P. Conti, C. Bartoli, A. Franco, D. Testi, Experimental Analysis of an Air Heat Pump
695 for Heating Service Using a "Hardware-In-The-Loop" System, *Energies* 13 (2020) 1-18.
- 696 [29] L. Frison, M. Kleinstück, P. Engelmann, Model-predictive control for testing energy
697 flexible heat pump operation within a Hardware-in-the-Loop, *J Phys Conf Ser* 1343 (2019)
698 1-6.
- 699 [30] P. Mehrfeld, M. Nürenberg, M. Knorr, L. Schinke, M. Beyer, M. Grimm, M. Lauster;
700 D. Müller, J. Seifert, K. Stergiaropoulos, Dynamic evaluations of heat pump and micro
701 combined heat and power systems using the hardware-in-the-loop approach, *J Build Eng*
702 28 (2020) 1-14.
- 703 [31] Matlab-Simulink software, <https://it.mathworks.com/products/simulink.html>
704 (Accessed August 29th 2022).
- 705 [32] Solar-Institut Juelich, CARNOT-Blockset, 1999. Germany Scientific Computers
706 GmbH.

- 707 [33] J.P. Campana, G.L. Morini, BESTEST and EN ISO 52016 Benchmarking of
708 ALMABuild, a New Open-Source Simulink Tool for Dynamic Energy Modelling of
709 Buildings, *Energies* 12, (2019), 2938.
- 710 [34] R.J. Moffat, Describing the uncertainties in experimental results, *Exp. Thermal*
711 *Fluid Sc.* 1 (1998) 1-17.
- 712 [35] J. Acuña, B. Palm, Distributed thermal response tests on pipe-in-pipe borehole heat
713 exchangers, *Appl. Energy* 109 (2013) 312-320.
- 714 [36] UNI EN 14511-3:2018, Air conditioners, liquid chilling packages and heat pumps for
715 space heating and cooling and process chillers, with electrically driven compressors - Part
716 3: Test methods.
- 717 [37] EUROVENT, Third party certification - Certita Eurovent, [https://www.eurovent-](https://www.eurovent-certification.com/en)
718 [certification.com/en](https://www.eurovent-certification.com/en) (Accessed August 29th 2022).
- 719